


LAMP PHOTOMETRIC REPORT

MODEL: 99POMT30/BL		
POWER: 15W	VOLTAGE: 230V	WORKING VOLTAGE: 230V
MANUFACTURER: Elmark Industries JSC		

TOTAL FLUX: 1260.5 lm



$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%
10	488.4	488.0	486.2	483.5	481.4	481.2	483.5	486.7	0- 10	46.84	46.84	3.72
20	457.0	455.7	452.9	448.8	444.5	443.3	447.7	454.1	10- 20	132.5	179.4	14.2
30	405.9	403.9	401.2	396.7	390.3	387.6	394.1	403.0	20- 30	196.2	375.6	29.8
40	341.2	337.5	335.2	331.9	324.2	319.3	327.5	338.6	30- 40	228.9	604.4	48
50	267.6	263.4	260.2	260.0	250.7	245.7	253.0	266.5	40- 50	228.1	832.6	66
60	189.3	186.0	182.2	184.5	175.1	170.6	176.4	190.7	50- 60	197.0	1030	81.7
70	109.5	109.1	105.8	109.2	100.6	97.06	101.4	114.9	60- 70	142.2	1172	93
80	38.46	38.44	36.04	40.81	32.75	31.08	34.01	44.80	70- 80	74.21	1246	98.8
90	1.358	0.8048	4.615	0.8874	1.021	0.7831	2.574	0.6489	80- 90	14.53	1261	100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 10.0DEG  
Test Speed: HIGH  
Temperature:25.3°C  
Operators:  
Test Date:15 November 2022

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 2.5DEG  
Test System:EVERFINE GO-2000A\_V1 SYSTEM V2.00.456  
Humidity:65.0%  
Test Distance:6.265m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```